CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD SAN FRANCISCO BAY REGION

ORDER NO. 77-111

NPDES NO. CA0037427

ORDER AMENDING ORDER NOS. 75-1 AND 76-43 TO ADOPT REVISED REQUIREMENTS AND TIME SCHEDULE FOR:

SANITARY DISTRICT NO. 5 - PARADISE COVE PLANT MARIN COUNTY

The California Regional Water Quality Control Board, San Francisco Bay Region, finds that:

- 1. The Regional Board on January 21, 1975 adopted Order No. 75-1 (NPDES Permit No. CA0037427) prescribing waste discharge requirements and compliance time schedules for Sanitary District No. 5, of Marin County, Paradise Cove Plant.
- 2. The Regional Board on May 4, 1976 adopted Order No. 76-43 prescribing revised waste discharge requirements and compliance time schedules for Sanitary District No. 5, of Marin County, Paradise Cove Plant.
- 3. The District is participating in the Marin Sonoma Subregional Agency Study to comply with certain effluent and receiving water limitations contained in Order No. 75-1. Completion of draft Environmental Impact Report/Environmental Impact Statement has been delayed due to delays in promulgation of specifications for Bay studies by the State Board and the adoption of the marsh policy by this Regional Board.
- 4. This project involves the continued operation of a publicly-owned facility to provide sewerage service with negligible or no expansion of use beyond that previously. Consequently, this project will not have a significant effect on the environment based upon the exemption provided in Section 15101, Title 14, California Administrative Code.
- 5. The Board has notified the discharger and interested agencies and persons of its intent to prescribe revised requirements for Sanitary District No. 5 of Marin County, Paradise Cove Plant.
- 6. The Board in a public meeting heard and considered all comments pertaining to this discharge.

IT IS HEREBY ORDERED, that the Regional Board amends Order Nos. 75-1 and 76-43 to read as follows:

Effluent Limitation A.5.

The total coliform bacteria for a median of five consecutive effluent samples shall not exceed 240 per 100 milliliters. Any single sample shall not exceed a most probable number (MPN) of 10,000 total coliform bacteria per 100 ml when verified by a repeat sample taken within forty-eight (48) hours.

Provision D.2.a.

Compliance with Effluent Limitations A.l.e., A.3., and Receiving Water Limitation B.2.c.:

<u>Task</u>	Completion Date	Report of Compliance Due
Publish completed Draft EIR/EIS and draft facilities plan	October 1, 1977	October 15, 1977
Hold public hearing on Draft EIR/EIS	November 15, 1977	November 30, 1977
Complete institutional arrangements necessary to implement facilities plan	January 1, 1978	January 15, 1978
Publish and submit Final EIR/EIS and submit project report and Step II grant application to SWRCB and this Board.	May 1, 1978	May 15, 1978
Submit necessary applications for NPDES permits including time schedule for design and construction of facilities to meet		
requirements	May 1, 1978	

I, Fred H. Dierker, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region, on September 20, 1977.

FRED H. DIERKER Executive Officer